

TS 316

## **Operating Principle**

TS 316 is a 6-input module for processing controls from automatism or control units TS 316 transmits the state of inputs following EIB bus switch-on.

The module also allows for the connection of push-buttons to indicator lights.

## **Technical Specifications**

- **Electrical Characteristics**
- Supply voltage: bus EIB 29 V
- Type of contact to be connected: push-button or switch.
- Terminal voltage of open contacts: 230 V -15 +10%
- Phase monitored: 230 V $\sim$  50 Hz • Detection of power OFF:
- Inputs to be wired to the monitored phase. • Current of closed contacts: 34 mA
- · Neon lamps max current of push-buttons with indicator light:
- 1 mA (with a max of 10 lamps).
- Maximum connection distance per input: 100 m.

#### **Functional characteristics**

Minimum contacts closing time: 50 ms

### Environment

<ul> <li>Operating T°:</li> <li>Storage T°:</li> </ul>	0 °C to +45 °C -20 °C to +70 °C
--	------------------------------------

### Connection

Capacity: flexible:	1 mm <sup>2</sup>	to 6 mm <sup>2</sup>
rigid:	1,5 mm <sup>2</sup>	to 10 mm <sup>2</sup>

### Dimensions

Size: 4 modules

User instructions

6-Input Module for installation in DIN rail enclosures


(GB)

## Warning :

This device shall be installed only by a qualified electrician.

- Follow TBTS installation rules.

### **Electrical connection**



Note: The various inputs may be connected to different phases.

### Installation instructions

- 1. Install module in bottom of enclosure to prevent excessive operating temperature.
- 2. Connect module to network and EIB bus.
- 3. Connect module inputs (1 to 6) to contacts of automatism, push-button or switches.
- 4. Follow instructions of system set-up.

# Warranty



A warranty period of 24 months is offered on hager products, from date of manufacture, relating to any material of manufac-turing defect. If any product is found to be defective it must be returned via the installer and supplier (wholesaler). The warranty is withdrawn if : - after inspection by hager quality control dept the device is found to have been installed in a manner which is contrary to IEE wiring regulations and accepted practice within the indus-try at the time of installation. - the procedure for the return of goods has not been followed. Explanation of defect must be included when returning goods.

3